

Government Of West Bengal Office Of The Divisional Fire Officer,Paschim Bardhaman West Bengal Fire & Emergency Services Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Memo no.: IND/WB/FES/20192020/56915

From: Divisional Fire Officer,Paschim Bardhaman West Bengal Fire & Emergency Services

To: Purv International School. A unit of Om Educational Trust.

Holding no. N/361, Ward no. 01, Kamalpur, Durgapur, Mouza Parulia, Plot no. R.S 324, 326, 327, 328, L.R 342, 343, 344, 347, J.L no. R.S 44, L.R 113, P.S Durgapur, Dist. Paschim Bardhaman, Pin - 713204

Sub: Renewal of Fire safety Certificate for a G+III storied under group Educational Building at the Holding no. N/361, Ward no. 01, under D.M.C, Kamalpur, Durgapur, Mouza - Parulia, Plot no. R.S 324, 326, 327, 328, L.R 342, 343, 344, 347, J.L no. R.S 44, L.R 113, P.S - Durgapur, Dist. Paschim Bardhaman, Pin – 713204.

This is in reference to your application no. 0125191239100051 dated 10-02-2023 regarding the Renewal of Fire safety Certificate for a G+III storied under group Educational Building at the Holding no. N/361, Ward no. 01, under D.M.C, Kamalpur, Durgapur, Mouza - Parulia, Plot no. R.S 324, 326, 327, 328, L.R 342, 343, 344, 347, J.L no. R.S 44, L.R 113, P.S - Durgapur, Dist. Paschim Bardhaman, Pin – 713204.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

## Recommendation:

1.All the fire prevention and fire safety measures shall be maintained in good repair and efficient condition at all times in accordance with the provision of Section 11 C of West Bengal Fire service Act 1950 with up to date amendment.

2. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.

3.To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the building shall be strictly maintained.

4.Existing electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling.

5. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191239100051. Page : 1

Page : 1

Powered By Environment Powered By Environment Powered By

Date: 10-04-2023

building.

6. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and testing.

7. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

8. Electrical switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher confirming I.S. specification. 9. First aid Firefighting system shall be provided as per I.S. specification.

10.Arrangement shall have to be made for regular checking, testing and maintenance of all the Firefighting installation in the building to keep them in perfectly good working condition at all the times.

11.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.

12.Periodical flashing of water from the fire water pipe line shall be made to maintain efficient working performance of above mentioned system.

13. This F.S.C. is valid for 03(three) years from the date of issue of this letter.

14.R.F.S.C is to be obtained from the Divisional Fire Officer, West Bengal Fire & Emergency Services, for performances of all the Life and Fire Safety arrangements and installation of the building.

the occurrence of the occurren 16. another staircase to be made in the building to avoid Dead End in the occupancy within 6 months otherwise the RFSC will be treated as cancelled

Signature Not Verified Digitally signed by SHYAM CHANDRA MONDAL Date: 2023.04.10 15:33:03 IST

Divisional Fire Officer, Paschim Bardhaman West Bengal Fire & Emergency Services

Powered By

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191239100051.

Page: 2