



DURGAPUR MUNICIPAL CORPORATION

CITY CENTRE, DURGAPUR -713216, DIST- PASCHIM BARDHAMAN

EPABX ⇨ (0343) 2545842, 2546994, 2546107 • Fax No. : 254-6472

Website : durgapurmunicipalcorporation.org • E-mail: durgapurcorporation@gmail.com

Ref. No : DMC/ WS/1986


Date 31/01/25

To

Director & Founder Principal
Purv International School,
Nachan Raod,
Kamalpur,
Durgapur-04

From report (Copy enclosed) submitted on 27-01-2025 by the
Engineers of DMC, it is found that the water supplied by DMC is safe
for drinking.

This is being issued as per his application dated 11th November, 2024.


Secretary, 31/1/25

Durgapur Municipal Corporation.

DURGAPUR MUNICIPAL CORPORATION

WATER ANALYSIS REPORT

PHYSICAL, CHEMICAL AND BACTERIOLOGICAL TEST

Place: PURV INTERNATIONAL SCHOOL, Kamulpur, Durgapur

Sample Name: Drinking Water

Sampling date: 16/01/25

Date: 24/01/25

SL NO	PARAMETERS	UNIT	Recommended Drinking Water Quality as per IS 10500 2012		Result
			DESIRABLE LIMIT	PERMISSIBLE LIMIT	
1.	Turbidity	NTU	1	5	0.40
2.	pH		6.5-8.5	6.5-8.5	8.02
3.	Temperature	Deg c			25.0
4.	Residual chlorine	Mg/l.Min	0.2	1	0.20
5.	Taste	Qualitative	Agreeable	Agreeable	Agreeable
6.	Odour	Qualitative	Agreeable	Agreeable	Agreeable
7.	Alkalinity	Mg/l.Max	200	600	102
8.	Chloride as cl	Mg/l.Max	250	1000	18.02
9.	Total Hardness	Mg/l.Max	200	600	124
10.	Calcium Hardness	Mg/l.Max	200	600	74
11.	Total Coliform	MNP/100 MI	Absent	Absent	Absent
12.	Fecal Coliform	MNP/100 MI	Absent	Absent	Absent

Water is safe according to this sample result.

Chinmay Banerjee

Tested by
DMC

27/1/25

SAE
DMC

27-1-25

AE
DMC